

















Protective Rubber Equipment Labeling Chart

for Salisbury Linemen's Natural Rubber and SALCOR® Rubber Protective Equipment

Class Color	Proof Test Voltage AC / DC	Max. Use Voltage* AC / DC	Rubber Molded Products Label	Insulating Rubber Glove Label	Insulating Rubber Dipped Sleeve Label	ASTM Specification Reference
00 Beige	2,500 / 10,000	500 / 750				D120 Rubber Insulating Gloves D178 Rubber Insulating Matting D1048 Rubber Insulating Blankets D1049 Rubber Insulating Covers D1050 Rubber Insulating Line Hose D1051 Rubber Insulating Sleeves
0 Red	5,000 / 20,000	1,000 / 1,500				F478 In-Service Care of Line Hose & Covers F479 In-Service Care of Insulating Blankets
1 White	10,000 / 40,000	7,500 / 11,250				F496 In-Service Care of Gloves & Sleeves F696 Leather Protectors for Insulating Gloves and Mittens
2 Yellow	20,000 / 50,000	17,000 / 25,500				F1236 Inspection Guide for Rubber Products F1742 PVC Insulating Sheeting
3 Green	30,000 / 60,000	26,500 / 39,750				F2320 Rubber Insulating Sheeting F2677 Electrically Insulating Aprons
4 Orange	40,000 / 70,000	36,000 / 54,000				Type I- Designates natural rubber. Type II- Designates SALCOR® UV and ozone resistant rubber.

* Max. Use Voltage when worn with leather protectors.

Insulating Gloves and Sleeves must have a color coded label to meet appropriate ASTM Specifications.

REQUEST THE BEST WITH SALISBURY

Part #ASTMCHART updated 110608 7.5M
© Salisbury by Honeywell

SALISBURY

by Honeywell

7520 N. Long Ave. Skokie IL 60077

toll free ph. 877.406.4501

toll free fax 866.824.4922

whsalisbury.com